



Town of Oak Bluffs, Massachusetts
BOARD OF HEALTH
P.O. Box 1327
Oak Bluffs, MA 02557

Patricia Bergeron, Chm
William White
James Butterick

Ade Solarin
Health Agent

Telephone: (508) 693-3554 ext. 116
Fax: (508) 693-6280

**BOARD OF HEALTH MEETING
AGENDA (Amended)
June 7th, 2016: 10:00 a.m. * Town Hall Meeting Room**

APPOINTMENTS:

10:00: Minute approval for 3/1/2016, 3/8/2016 and 3/15/2016 meetings

10:05: Review with Health Agent

10:10: 19 Hampson Avenue M 8 P.190: Re Variance Request

The following variances from Title 5 are being requested:

- 1) *To reduce the required distance from soil absorption system to a property line from 10' down to 2'*
- 2) *To reduce the required distance from soil absorption system to a cellar wall from 20' down to 16'*
- 3) *To reduce the required distance from septic tank to a property line from 10' down to 5'*
- 4) *To reduce the required distance from septic tank to a cellar wall from 10' down to 7'*
- 5) *To increase maximum depth from finish grade to the top of leaching field from 36" to 48"*

10:20: 78 Isaac Avenue M. 22 P.66.3: Re Variance Request

15.240(5): To allow the construction of one bedroom sewage disposal system on 10,913± square feet of area

10:30: Morgan Douglas Re: Water Fluoridation

Request to discontinue practice of Water Fluoridation in the Town of Oak Bluffs

10:40: Alan Robillard: Discussion of Lagoon Ridge Project shortcomings

MEMBERS:

HEALTH AGENT:

- Grease Trap Regulation discussion
Discussion of the draft copy of regulation presented during previous meetings
- Policy Discussion
Discussion of existing and proposed policies for Oak Bluffs Board of Health

Oak Bluffs, MA
Town Clerk's Office

6-3 2016

925
Rec'd for Record
AT H M M